



NOTICE TO ALL FIRMS

Date: May 6, 2025

To: All Prospective Bidders

From: Sam Li
Director of Procurement Services

Re: Addendum Number 6
IFB # C1585 – Pomerantz New Fire Alarm System

Questions

- Q1. We just got an email from our switchgear company stating that **As per Asco they had to upsize the ATS from 125A to 600A to comply with 30 Cycle requirements on the specs.** Please confirm if this is acceptable?
- A1. **The ATS should remain sized at 125A. The 30Cycle requirement should be omitted for this unit.**

THIS ADDENDUM IS PART OF THE CONTRACT DOCUMENT AND SHALL BE INCLUDED WITH YOUR REQUEST FOR PROPOSAL SUBMITTAL. YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.

Signature

Print Name and Title of Authorized Representative

Print Name of Company/Partnership/Individual

Date