



NOTICE TO ALL FIRMS

Date: January 28, 2025

To: All Prospective Bidders

From: Sam Li
Director of Procurement Services

Re: Addendum Number 6
IFB # C1592 – Goodman Lower Level Gallery New HVAC Unit

Notes:

There will be no more bid extensions. The bids are due tomorrow, January 29, 2025, 12:00 PM. We must receive the bids on or before January 29, 2025, 12:00 PM.

Questions:

Q1. I apologize for sending yet another RFI on this contract at this late stage, but the specified water treatment vendor has just issued their proposal this morning and they have many questions that are preventing them (and us from pricing) this properly. Can we please get a response to the following prior to bid?

“The project specification for water treatment is written as though for a completely new piping system and not as an integration into an existing system with existing treatment equipment. Nothing is shown on the drawings for water treatment. Please clarify what the scope of work is for water treatment on this project. Indicate what existing equipment is to remain and what is expected to be new. Please provide a piping diagram showing this equipment and clarifying the requirement. Additionally, please indicate if a glycol makeup system is required and indicate its installation on the drawings.”

A1. The cleaning in the specification is for all new glycol piping shown on the plans. The water treatment is for an additional cooling tower and it should be extended from the existing chemical treatment for two towers. The glycol makeup station is existing and the contractor has to connect the new pipes as shown on the roof plan.

THIS ADDENDUM IS PART OF THE CONTRACT DOCUMENT AND SHALL BE INCLUDED WITH YOUR REQUEST FOR PROPOSAL SUBMITTAL. YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.

Signature

Print Name and Title of Authorized Representative

Print Name of Company/Partnership/Individual

Date