



**NOTICE TO ALL FIRMS**

Date: May 28, 2026  
To: All Prospective Bidders  
From: Sam Li  
Director of Procurement Services  
Re: Addendum Number 3  
RFP # C1748 – Interior Architectural Design and Related Services  
for Presidential Housing

**Note:**

Please note that the response to Question 46 in Addendum 2 was issued in error. The correct response is that the apartment is served by two (2) 100-amp electrical panels.

**THIS ADDENDUM IS PART OF THE CONTRACT DOCUMENT AND SHALL BE INCLUDED WITH YOUR REQUEST FOR PROPOSAL SUBMITTAL. YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.**

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Print Name and Title of Authorized Representative

\_\_\_\_\_  
Print Name of Company/Partnership/Individual

\_\_\_\_\_  
Date