



NOTICE TO ALL FIRMS

Date: October 6, 2022

To: All Prospective Bidders

From: Sam Li
Deputy Director of Purchasing

Re: Addendum Number 2
IFB # C1536 – Admissions Office Renovation

Questions:

- Q1. Specification section 02 08 30, Removal of Universal Waste and Miscellaneous Hazardous Materials requires the removal and proper disposal of various item deemed hazardous. However, the table for the materials to be removed is blank. Please clarify if this scope of work is required.
- A1. The form should be blank. The hazardous materials are identified in a list, under the form. The GC can estimate based on the walk through the quantity of material to be removed that falls under these categories. Then, once he starts removing it, he submits this form filled out. For example, he may remove 3 fluorescent bulbs, one electrical panel etc. The GC must call a hauler of hazardous material and ask for the haul costs for the amount of hazardous items that need to be disposed from NYC to the nearest landfill. He will then include that figure in his bid.

THIS ADDENDUM IS PART OF THE CONTRACT DOCUMENT AND SHALL BE INCLUDED WITH YOUR REQUEST FOR PROPOSAL SUBMITTAL. YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.

Signature

Print Name and Title of Authorized Representative

Print Name of Company/Partnership/Individual

Date