



NOTICE TO ALL FIRMS

Date: November 29, 2023

To: All Prospective Bidders

From: Sam Li
Interim Director of Procurement Services

Re: Addendum Number 2
IFB # C1558 – East Courtyard & Pomerantz Center Air Handler Units Replacement

Questions

- Q1. Please look into possibility for the mechanical prime contractor to bid on modification of existing unit support dunnage. I know that I will not have any control over how the factory will fabricate the replacement AHU. Therefore I do not want any conflict with a third party steel fabricator. Allow me to submit additional bid to FIT for dunnage work. I will provide my shop drawings of modified dunnage to match footprint of new AHU AC-2D.
- A1. The prime HVAC contractor has full control of the construction of the AC-2D unit and the replacement unit shall be manufactured and coordinated to be installed on the existing dunnage. It is the responsibility of this contractor to provide a turnkey project and no separate bid will be allowed. The contractor shall coordinate the existing dunnage and field conditions prior to release the fabrication of the unit.

THIS ADDENDUM IS PART OF THE CONTRACT DOCUMENT AND SHALL BE INCLUDED WITH YOUR REQUEST FOR PROPOSAL SUBMITTAL. YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.

Signature

Print Name and Title of Authorized Representative

Print Name of Company/Partnership/Individual

Date