



NOTICE TO ALL FIRMS

Date: June 21, 2023

To: All Prospective Bidders

From: Sam Li
Deputy Director of Purchasing

Re: Addendum Number 1
IFB # C1576 – D442 Classroom Renovation

Questions:

- Q1. FR Door #1 calls for hardware set #1 – I didn't find Hardware Schedule neither in drawings set, nor in spec. What should I price – standard? Or you would send me HW set description?
- A1. Hardware sets are included in the specifications, 08 06 71 Hardware Schedule.
- Q2. Glass Marker Boards – Detail 10/ A-700 asks for Thru-mount Clips, but shows z-clip installation. Which one is correct? Also, "Continuous Horizontal 12 ga metal plate secured to studs" – by others.
- A2. Re-read the detail. The clips are Trumount Clips manufactured by the glass board manufacturer, Clarus. No z-clips are shown. The continuous 12 ga. metal plate is NOT by others. This is to be installed by the Contractor.

THIS ADDENDUM IS PART OF THE CONTRACT DOCUMENT AND SHALL BE INCLUDED WITH YOUR REQUEST FOR PROPOSAL SUBMITTAL. YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.

Signature

Print Name and Title of Authorized Representative

Print Name of Company/Partnership/Individual

Date