



## NOTICE TO ALL FIRMS

Date: September 5, 2023  
To: All Prospective Bidders  
From: Sam Li  
Deputy Director of Purchasing  
Re: Addendum Number 4  
IFB # C1590 – Museum Lighting (GC)

### **Note:**

- 1) This is a reminder that the bids are due tomorrow, **September 6, 2023, 12:00 PM**. Your bid must be emailed to [Purchasingbids@fitnyc.edu](mailto:Purchasingbids@fitnyc.edu) by **September 6, 2023, on or before 12:00 PM**.

### **Question:**

- Q1. Isn't there another alternate if ceiling is plaster instead of gypsum board for demolition?
- A1. The base bid is a gypsum board ceiling in the taller space. The add alternate is the acoustic ceiling in the taller space. There is no add alternate in the shorter space as it will get a gypsum board ceiling. In all scenarios the existing ceiling in both spaces is to be demolished and removed.

**THIS ADDENDUM IS PART OF THE CONTRACT DOCUMENT AND SHALL BE INCLUDED WITH YOUR REQUEST FOR PROPOSAL SUBMITTAL. YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.**

---

Signature

---

Print Name and Title of Authorized Representative

---

Print Name of Company/Partnership/Individual

---

Date