



## NOTICE TO ALL FIRMS

Date: March 25, 2024

To: All Prospective Bidders

From: Sam Li  
Interim Director of Procurement Services

Re: Addendum Number 2  
IFB # C1591 – Pomerantz Center Fire Pump Replacement

### Notes:

- 1) We are releasing the hold on this bid.
- 2) Please see answers to the RFI below.
- 3) ***The new bid due date is Monday, April 1, 2024, 12:00 PM. We must receive the bids on or before April 1, 2024, 12:00 PM.***

### Questions

- Q1. A 2 week duration for shut down seems pretty tight, can we get an extension of another 2 weeks for the shut down?
- A1. Contractor should schedule in the bid a 3 week shutdown for the fire pump replacement. FIT will provide up to 3 weeks fire watch. If the installation of the fire pump extends beyond the 3 weeks, contractor is responsible for the fire watch for the entire building which must be included in the cost of their bid.

**THIS ADDENDUM IS PART OF THE CONTRACT DOCUMENT AND SHALL BE INCLUDED WITH YOUR REQUEST FOR PROPOSAL SUBMITTAL. YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.**

---

Signature

---

Print Name and Title of Authorized Representative

---

Print Name of Company/Partnership/Individual

---

Date