



### **NOTICE TO ALL FIRMS**

Date: May 6, 2024  
To: All Prospective Bidders  
From: Sam Li  
Interim Director of Procurement Services  
Re: Addendum Number 2  
IFB # C1632 – Alumni Residence Hall Exhaust Riser Repairs Line A, B, & C

#### **Questions**

- Q1. As per drawing M-701.00 the schedule shows the Mitsubishi air cooled condensing unit having cooling capacity 66000 BTU/h and both indoor units having cooling capacity 24000 BTU/h each, with a total of 48000 BTU/h, as the cooling capacities do not match, please advise.
  - A1. The 66,000 BTU/h is heating capacity. The cooling capacity is 60,000 BTU/h. The outdoor unit capacity can be higher than the sum of indoor units' capacity to allow for future addition of indoor units.
- Q2. The manufacturer Mitsubishi stated that they do not make these units anymore, please advise.
  - A2. Please request the replacement model for this unit from Mitsubishi. They have to be heat pump models.
- Q3. There are no specifications for the equipment specified as per drawing M-700.00, please advise.
  - A3. The equipment shall be as per specified model on M-701 or approved equal.

**THIS ADDENDUM IS PART OF THE CONTRACT DOCUMENT AND SHALL BE INCLUDED WITH YOUR REQUEST FOR PROPOSAL SUBMITTAL. YOUR SIGNATURE BELOW WARRANTS THAT YOU UNDERSTAND THIS ADDENDUM AND THAT YOU HAVE MADE THE APPROPRIATE ADJUSTMENTS IN YOUR PROPOSAL AND CALCULATIONS.**

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Print Name and Title of Authorized Representative

\_\_\_\_\_  
Print Name of Company/Partnership/Individual

\_\_\_\_\_  
Date